



NOTE: A 1" DRAIN WILL BE REQUIRED ON THE LOWER END OF THE CASING IF THE CASING ENDS ARE SEALED WITH MORTER AND BRICK.

REVISIONS				PIPE SUPPORT IN CASING PIPE	DRAWING
NO.	DATE				W-22
ORIGINAL	12/01/06				